

Certificate

No.: 968/FSP 1578.01/18


Manufacturer	KLINGER Fluid Control GmbH Am Kanal 8-10 A-2352 Gumpoldskirchen
Test item	Ballostar® KHA (3-parts) and KHE (2-parts)
Type designation	KHA – FL / FK and KHE – FL / FK
Intended use	Temperature range: -40 °C to +80 °C Nominal pressure: PN 16 and PN 40 Nominal width: DN15 – DN125 (KHE-FK up to DN200) Actuator: Model series AT-xxxU-SR10-DS Brand: AIR TORQUE S.p.A.
Codes and Standards	DIN EN 161:2013-04 EN 161:2011+A3:2013
Test result	This confirms the conformity of the test object with the test requirements
Special terms & conditions	The notes in the associated installation and operating instructions must be observed.
Valid until	03/2023

The issue of this certificate is based on an examination, whose results are documented in Report-No.: 968/FSP 1578.01/18 dated 2018-03-27.

This certificate is only valid for products which are identical with product tested. It becomes invalid in case of any modification of the products or withdrawal of the listed test basis.

Cologne, 2018-03-27

TÜV Rheinland Industrie
Service GmbH
51105 Cologne - Germany



Dr.-Ing. Thorsten Gantevoort

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln